

## ATTACHMENT 1

This attachment is integral part of  
Approval Nr.1853–PED–18293 FU1 of ENTROPIE Heizungssysteme GmbH

List of equipment with EU-Type examination – production type  
Included in the scope of approval № 1853–PED–18293 FU1

No	Equipment	No of certificate of type examination	Maximum allowable pressure P <sub>s</sub> (bar)	Maximum allowable temperature (°C)
1.	Gas – Hot Water Boiler TT150 (ЭФ.312.00.000 СБ; ЭФ.3121.00.000 СБ)	2595 202 CZ-B-180322	10,0	150
2.	Steam Boiler TT200 (EF 266E.000.000; EF 266E.002.000 KSS)	2595 202 CZ-B-190266	16,0	204

Remark: EU-Type examination certificates are not applied separately

Sofia, 16.10.2019  
(Location and date of issue)

Head of Notified Body for Pressure Equipment and  
Simple Pressure Vessels:

